



“Gheorghe Asachi” Technical University of Iasi, Romania



INDOOR AIR QUALITY INVESTIGATION AND HEALTH RISK ANALYSIS IN INDIAN TEXTILE-SIZING MILLS

**Shankar Subramaniam^{1,8*}, Abbas Ganesan², Naveenkumar Raju³,
Nithyaprakash Rajavel⁴, Maheswari Chenniappan⁵, Chander Prakash^{6,7}**

¹Department of Mechanical Engineering, Nandha Engineering College, Erode, India

²Department of Mechanical Engineering, Karpagam Institute of Technology, Coimbatore, India

³Department of Mechanical Engineering, Kongu Engineering College, Erode, India

^{4,5}Department of Mechatronics Engineering, Kongu Engineering College, Erode, India

⁶Research and Innovation Cell, Rayat Bahra University, Mohali-140301, Punjab, India.

⁷Department of Mechanical Engineering, Rayat Bahra Institute of Engineering and Nano Technology, Hoshiarpur, Punjab, India

⁸Department of Mechanical Engineering, Karpagam College of Engineering, Coimbatore, India

Abstract

The study aimed to evaluate indoor air quality (IAQ) in textile sizing mills in Tamil Nadu, India, focusing on pollutants such as PM_{2.5}, PM₁₀, total volatile organic compounds (TVOCs), carbon dioxide (CO₂), and carbon monoxide (CO). These pollutants were monitored using the Oizom Polludrone, a real-time air quality monitoring system equipped with optical particle counters, photoionization detectors, and non-dispersive infrared sensors designed to monitor key indoor air pollutants, including particulate matter (PM_{2.5}, PM₁₀), total volatile organic compounds (TVOCs), carbon dioxide (CO₂), and carbon monoxide (CO), as well as temperature and relative humidity. Measurements were taken over 10 days at a height of 1.5–2 meters to capture worker breathing zone concentrations. Key findings revealed that PM_{2.5} and PM₁₀ levels were highest in the wrapping section due to cotton dust, while TVOC levels peaked in the sizing section, attributed to the use of adhesives, binders, and chemicals. Night-time concentrations exceeded daytime levels, primarily due to reduced ventilation, and pollutant levels frequently surpassed OSHA and NAAQS standards. Health risks were quantified using hazard quotient (HQ) and hazard index (HI), showing significant risks in the sizing section. The results confirmed interdependencies between pollutants, showing that changes in one pollutant were often linked to changes in others. Recommendations include advanced ventilation systems, low-emission sizing agents, PPE usage, and regular air quality monitoring to safeguard worker health and ensure compliance with safety standards.

Key words: Air Quality, Hazard Quotient, Oizom Polludrone, Textile Sizing Mill, TVOC

Received: August, 2023; Revised final: June, 2025; Accepted: August, 2025
