



**“Gheorghe Asachi” Technical University of Iasi, Romania**



---

## **THERMAL COMFORT AND VENTILATION CONDITIONS IN HEALTHCARE FACILITIES - PART 1: AN ASSESSMENT OF INDOOR ENVIRONMENTAL QUALITY (IEQ)**

**Mawara Khan<sup>1</sup>, Muhammad Jamaluddin Thaheem<sup>2\*</sup>, Musfira Khan<sup>3</sup>,  
Ahsen Maqsoom<sup>4</sup>, Muhammad Zeeshan<sup>5</sup>**

<sup>1</sup>*Department of Construction Engineering & Management, School of Civil and Environmental Engineering, National University of Sciences and Technology, Islamabad, Pakistan*

<sup>2</sup>*School of Architecture and Built Environment, Faculty of Science, Engineering & Built Environment, Deakin University, Geelong, Australia*

<sup>3</sup>*Department of Computer Science, School of Electrical Engineering and Computer Science, National University of Sciences and Technology, Islamabad, Pakistan*

<sup>4</sup>*Department of Civil Engineering, COMSATS University Islamabad, Wah Campus, Pakistan*

<sup>5</sup>*Institute of Environmental Sciences and Engineering, School of Civil and Environmental Engineering, National University of Sciences and Technology, Islamabad, Pakistan*

---

### **Abstract**

Healthcare facilities provide a cure from the ailment while maintaining a clean environment. A high indoor environmental quality (IEQ) can improve the recovery process and create a pleasant working environment, while a poor IEQ causes nosocomial diseases that are harmful to the patients as well as the hospital staff. To assess the state of IEQ in selected local hospitals, the current study investigates critical IEQ parameters. Based on a detailed literature synthesis, three parameters are selected (temperature, relative humidity, and CO<sub>2</sub>) for IEQ assessment in four local hospitals. Four different locations (emergency room, OT, ICU, and medical ward) in each hospital are considered with respect to the existing heating, ventilation, and air conditioning (HVAC) system. Data is recorded on a 5-min interval for 6 days uninterrupted and the mean hourly value for each location is calculated for 24 hours. Statistical analysis is performed to compare the day- and night-time IEQ trends. A significant difference is found in the day- and night-time observations for OTs, while random trends are noticed in emergency areas. The results show that occupancy rate, ambient thermal conditions, type of HVAC system, and building orientation are vital drivers of IEQ. In conclusion, design and retrofitting recommendations are provided.

**Keywords:** CO<sub>2</sub> concentration, healthcare facilities, HVAC system, indoor environmental quality, thermal comfort

*Received: May, 2019; Revised final: December 2019; Accepted: December, 2019; Published in final edited form: June, 2020*

---

\* Author to whom all correspondence should be addressed: e-mail: [jamal.thaheem@deakin.edu.au](mailto:jamal.thaheem@deakin.edu.au)